


Pietra

The Pietra Range is a sophisticated ceramic tile collection that captures the timeless elegance of natural stone, offering durability and effortless style for a variety of spaces. Designed for indoor applications, this range is available exclusively in a 600x600mm format, making it a versatile and practical choice for both residential and commercial settings. With its refined stone-like texture and subtle veining, Pietra is available in three classic colours: Cream, Ivory, and Grigio, providing a neutral and elegant palette that complements a wide range of interior and exterior designs. Combining natural beauty with low-maintenance and high-performance qualities, the Pietra Range is perfect for creating seamless, sophisticated surfaces that enhance any environment.


COLOURS



Cream



Grigio



Ivory

FORMATS



600 x 600mm

FINISH: **MATT** | CATEGORY: CERAMIC TILES | EDGE DETAIL: RECTIFIED | V RATING: V3



Cream



600 x 600mm
PIETCR60 (Matt)

Grigio



600 x 600mm
PIETGR60 (Matt)



Ivory



600 x 600mm
PIETIV60 (Matt)



Technical Specification

	Properties	Test Method	Required Value	Value	Applies to
	Water absorption	EN ISO 10545-3	$\leq 0.5\%$	$\leq 0.5\% < 3\%$	Full range
	Determination of dimensions	EN ISO 10545-2	Length and width $\pm 0.6\%$ Thickness $\pm 5.00\%$ Transmutation $\pm 0.5\%$	Length and width $\pm 0.12\%$ Thickness $\pm 3\%$ Transmutation $\pm 0.1\%$	Full range
	Breaking strength	EN ISO 10545-4	≥ 1100 N	≥ 1606 N	Full range
	Modulus of rupture	EN ISO 10545-4	≥ 35 N/mm ²	≥ 37.3 N/mm ²	Full range
	Abrasion resistance	EN ISO 10545-7	≤ 205 mm ²	≤ 160 mm ²	Full range
	Slip resistance (wet pendulum test)	AS 4586-2013/ AMDT1-2017	N/A	P3	Matt
	Chemical resistance	EN ISO 10545-13	Min. GB	Class 5	Full range
	Stain resistance	ISO 10545-14	Min class 3	Class 5	Full range
	Origin	N/A	N/A	China	Full range
	Shade variation	N/A	N/A	V3	Full range

Packing Information

Tile description		Quantity per box	Quantity per m2		Quantity per pallet	
Size (mm)	Texture	Pieces	Pieces	Weight	m2	boxes
600 x 600	Matt	4	2.78	20.50kg	57.60	40



The data and information contained in these specification sheets are indicative only unless stated otherwise. As Japan Ceramics cannot control the conditions under which these products are manufactured, the specifications supplied should be considered as suggested guidelines only and are subject to batch variation. The information contained in these specification sheets should not be considered a warranty, expressed or implied, including, but not limited to, a warranty of merchantability or fitness for a particular purpose. To the maximum extent permitted by law, Japan Ceramics will not be responsible for damages of any nature resulting from the use or reliance upon the information contained in this data sheet. No express or implied warranties are given in respect of any specification provided herein other than those that cannot be excluded under the Australian Consumer Law.

Please note: Slip rating is indicative only. Actual performance may vary depending on installation, maintenance, cleaning, and environmental conditions. Customers should ensure suitability for their specific project requirements prior to installation.

Slip Check to AS 4586-2013

Pietra

Report Number: R34242

Report Date: 31 July 2025

Total Number of Pages 2

Safe Environments quality management system is certified to ISO 9001:2015

Accredited for compliance with ISO/IEC 17025 – Testing

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration, inspection, proficiency testing scheme providers and reference materials producers reports and certificates

Issued by

Safe Environments Pty Limited
6/7 Inglewood Place
Norwest NSW 2153

Prepared for

Japan Ceramics Pty Ltd
26 Daisy Street
Revesby NSW 2212

Approved by


Ratan Venkatesan
Authorised Signatory

31 July 2025

Test Report No. R34242

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586-2013 Appendix A (Wet Pendulum Test)

The slip resistance classification has been determined for unused surfaces under specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface after classification. Standards Australia Handbook 198:2014 *Guide to the specification and testing of slip resistance of pedestrian surfaces* provides guidance for the selection of slip resistant pedestrian surfaces classified in accordance with AS 4586-2013. It is recommended that this test report be read in conjunction with AS 4586, HB 197 & HB 198.

Requested by: Japan Ceramics Pty Ltd
Client Address: 26 Daisy Street
Revesby NSW 2212
Product Manufacturer: WenZhou J & F Foreign Trade Co., Ltd
Product Description: Pietra

Test conducted according to: AS 4586:2013 Appendix A
Sampling Procedures: Performed by client and tested as received.
Location: 6/7 Inglewood Place, Norwest NSW 2153

Conducted by: Ratan Venkatesan

Date: 31 July 2025
Sample: Unfixed
Rubber slider used: Slider 96
Slope of specimen: Tested on a flat level surface
Direction of Test: N/A

Temperature: 15°C
Cleaning: None
Conditioned: Grade P 400 paper dry followed by wet lapping film

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	50	51	49	49	50

Reported SRV of Sample:	50
Class:	P4

The expanded uncertainty (U_{95}) at the 95% level of confidence with a coverage factor (k) of 2 has been estimated to be 3 BPN or 8 %, whichever is the greater; sampling uncertainty has not been included. The expanded uncertainty should be considered when interpreting results or assessing conformity. Results relate only to items tested.